

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3175-1443:102 Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: AAF International, PO Box 35690, Louisville KY 40232-5690
Contact: David W. Miller (502) 637-0518

DESIGN: Model DRI-PAK. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, size, capacity, classification and UL label.

APPROVAL: Listed as filters for use in heating, ventilating, and air conditioning systems with capacities of 500-2500 CFM. Units with mesh scrim are classified as Class I filters; units with fiberglass scrim are classified as Class II filters.

NOTE: Formerly 3175-1390:102

Rev 05-26-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager